

Prop	Anteproyecto de NOM-XXX-CON, JA-2011 Aparatos y accesorios de uso sanitario.	OPUESTA	COMENTARIO
ANFAD	14 VIGILANCIA La vigilancia del cumplimiento de la presente Norma Oficial Mexicana en el ámbito de sus respectivas competencias será realizada por: a. La Secretaría de Medio Ambiente y Recursos Naturales por conducto de la Comisión Nacional del Agua, en los centros de producción; b. La Procuraduría Federal de Protección al Consumidor en los Puntos de Venta; c. La Secretaría de Hacienda y Crédito Público a través de la Administración General de Aduanas, en los puntos de ingreso al país;	14 VIGILANCIA La vigilancia del cumplimiento de la presente Norma Oficial Mexicana en el ámbito de sus respectivas competencias será realizada por: a. La Secretaría de Medio Ambiente y Recursos Naturales por conducto de la Comisión Nacional del Agua, en los centros de producción; b. La Procuraduría Federal de Protección al Consumidor en los Puntos de Venta;	

	PRODUCTO													
	Inodoro, mingitorio			lavabo			álvulas de admisión y descarga			Flujómetro			Sello obturador	
Legenda	Producto Marcado Permanente	Producto Etiquetado	Empaque solo cuando la información de la etiqueta del producto no sea visible	Producto Marcado Permanente o con etiqueta	Producto Etiquetado	Empaque solo cuando la información de la etiqueta del producto no sea visible	Producto Marcado Permanente	Información para el empaque individual del producto, excepto equipo	Producto Marcado Permanente	Información para el empaque individual del producto	Producto Marcado Permanente	Información para el empaque individual del producto, excepto equipo	Producto Marcado Permanente	Información para el empaque individual del producto, excepto equipo
Marca o Logotipo.		XXX	XXX		XXX	XXX	XXX	XXX		XXX	XXX	XXX	XXX	XXX
Legenda o Logotipo "Hecho en Mexico" o bien "Hecho en...		XXX	XXX		XXX	XXX		XXX		XXX	XXX			XXX
Modelo o tipo o clave de producto o contraseña que permita identificar el producto.	XXX	XXX	XXX		XXX	XXX	XXX	XXX		XXX		XXX	XXX	XXX
Número de Lote o Fecha de Fabricación.	XXX													
Contraseña Oficial.		XXX	XXX		XXX	XXX		XXX		XXX		XXX		XXX
Denominación o Razón Social del Fabricante o Importador.		XXX	XXX		XXX	XXX		XXX		XXX		XXX		XXX
Domicilio del Fabricante o Importador.		XXX	XXX		XXX	XXX		XXX		XXX		XXX		XXX
Consumo de Agua en Litros por Descarga.		XXX	XXX									XXX		
Grado de Calidad del Producto.		XXX	XXX		XXX	XXX								
Rango de Presión de Trabajo (cuando sea un inodoro asistido por presión).			XXX											
Tipo de accionamiento.												XXX		



Proposal for amendment

Project FX-08-08 Addition of mounting dimensions for wall-hung water closet fixtures

ASME A112.19.2-2008 / CSA B45.1-08 Ceramic plumbing fixtures

Note: *This draft is still under development and subject to change; it should **not** be used for reference purposes.*

© Canadian Standards Association and The American Society of Mechanical Engineers. All rights reserved. This draft is for CSA and ASME committee use only. No part of this draft may be reproduced or redistributed, in whole or in part, by any means whatsoever without the prior permission of CSA or ASME. Permission is granted to members of the committees that are responsible for the development of this draft to reproduce this draft strictly for purposes of CSA or ASME standards-development activity.

Canadian Standards Association
5060 Spectrum Way, Suite 100
Mississauga, Ontario, L4W 5N6

The American Society of Mechanical Engineers
Three Park Avenue
New York, NY, 10016-5990

Draft: No. 1a
Date: March 2010

Project title: Addition of mounting dimensions for wall-hung water closet fixtures
Project No.: FX-08-08 Standard: ASME A112.19.2-2008 / CSA B45.1-08

This proposal identifies deletions as text ~~strike through~~ and text additions as text underline.

Page 36

Insert the following revised figure 3:

The new figure 3 (c), (d), and (e) are the same as the existing 3 (a), (c), and (d).




Figure 3
Outlet dimensions for rear-outlet and
rear-spigot-outlet water closet bowls
(See Clause 4.6.1.)

Proposal for amendment

Project title: Addition of mounting dimensions for wall-hung water closet fixtures

Project No.: FX-08-08 Standard: ASME A112.19.2-2008 / CSA B45.1-08

This proposal identifies deletions as text ~~strike-through~~ and text additions as text underline.

Page 36

Delete the following figure 3 (existing):




Figure 3
Outlet dimensions for rear-outlet and
rear-spigot-outlet water closet bowls
(See Clause 4.6.1.)

Project title: Addition of mounting dimensions for wall-hung water closet fixtures
Project No.: FX-08-08 Standard: ASME A112.19.2-2008 / CSA B45.1-08

This proposal identifies deletions as text ~~strike through~~ and text additions as text underline.

Page 37

Edit Figure 4(c) as shown:




Figure 4
Bolt hole spacing for wall-mounted water closet bowls
(See Clause 4.6.3.)

Rationale:

Presently there are missing standard dimensions for the inlet and outlet openings for wall-hung water closets that are commonly used in Europe and are being approved for use in the US and Canada. This change will harmonize the dimensional requirements to insure the proper function of the fixtures with the carriers on which they are mounted.

Larry Himmelblau

2

[illegible]

